



**AMENDMENT NO.: 5 TO THE
TENDER DOCUMENTS**
Defence Construction (1951) Limited

T-11-1580

CLOSING DATE/TIME: December 20, 2011
14:00 hours, (local time)

PROJECT NO.: IE121143

AMENDMENT DATE: December 12, 2011


PROJECT TITLE: Construct Firehall
Trenton, Ontario

TO ALL PROPONENTS:

THE PURPOSE OF THIS AMENDMENT IS TO GIVE EFFECT TO THE FOLLOWING:

1. Bidders are advised that the closing date for this project has been changed from December 14, 2011 to **December 20, 2011**. The closing time and location remain unchanged.
2. To **ISSUE** Addendum No. 3, dated December 9, 2011 (1 pages attached)

End of Amendment No. 4



ADDENDUM # 3

of pages: 1

PROJECT: New Fire Hall
8 Wing Trenton

PROJ. NO.: H-T81-2306/1

DATE: Dec 9, 2011

.1 Civil Drawing 606:

In reference to the water main crossing of Meyers Creek, note that the nearest borehole (BH # 8) log indicates bedrock at elevation 76.14. Bidders are to assume that the top of solid bedrock at the water main crossing of Meyers Creek is also at 76.14 m. The water main depth below the creek is to be minimum 1.8 m below grade (bed of creek), and will be at about 75.5 m, indicating that the required creek crossing operation will be in solid rock, requiring rock tunnelling or drilling methods instead of jack and bore, as well as removal of bedrock at both ends to achieve the equipment rigging depth for the rock tunnelling.

.2 Incoming natural gas service:
Refer to Detail 3/421:
Delete Note 1 and replace with:

“The Contractor is to arrange for the incoming gas service and make application for service to the utility. Coordinate with site drawing 606 to confirm extent of piping required prior to bid. The Union Gas invoice cost will be paid by DCC via Change Order to the contractor. The contractor must carry their portion of the work including coordination, overhead and profit in their lump sum bid.”

End of Addendum